



**TOWN OF HULL**  
Sewer Department

1111 Nantasket Avenue  
Hull, MA 02045  
Tel: (781) 925-1207  
Fax: (781) 925-3771  
Email: [sewer@town.hull.ma.us](mailto:sewer@town.hull.ma.us)  
[www.town.hull.ma.us](http://www.town.hull.ma.us)

## **SANITARY SEWER OVERFLOW (SSO) PUBLIC NOTIFICATION HULL WASTEWATER TREATMENT FACILITY (WWTF)**

in accordance with 314 CMR 16.00

**NOTICE:** The discharge or overflow described in this notification consists, or likely consists, of untreated or partially treated sewage and waste.

Avoid contact with these water bodies for 48 hours after the discharge or overflow ceases due to increased health risks from bacteria and other pollutants. See <https://www.town.hull.ma.us/> for more information on whether specific resource areas, such as bathing beaches, are affected.

For additional information on discharges and overflows, and the Hull WWTF's SSO Abatement Program, please visit <https://www.town.hull.ma.us/sewer-department/pages/sanitary-sewer-overflow-public-notifications>. You can subscribe to receive E-Alerts at the top of the page.

### SSO Event Details

Notification Type	
<input type="checkbox"/> Initial-ongoing <input checked="" type="checkbox"/> Initial-ceased <input type="checkbox"/> Continuation <input type="checkbox"/> Cessation <input type="checkbox"/> Retraction	
Permittee: Hull Wastewater Treatment Plant	Permit #: MA0101231
Approximate date and time event began: 8/24/2022 9:45 am	
Approximate date and time of continuation notice: NA	
Approximate date and time event ceased: 8/24/2022 11am or <input type="checkbox"/> Ongoing	
Description of discharge or overflow location(s): Failed EOne grinder pump resulting in an overflow from holding tank.	
Waters and Land Areas, including names of water bodies and municipalities, effected or potentially affected by the discharge or overflow: Side yard at 55 Grosnold Street Hull, MA 02045	
Estimate volume of discharge:	30 gallons