

United Water - AOS  
1111 Nantasket Avenue  
Hull, Ma 02045-1313  
Tel # 781-925-0906  
Fax # 781-925-3056



May 10, 2010

Mr. Edward Petrilak  
Chief Facility Manager  
Town of Hull  
Water Pollution Control Facility  
1111 Nantasket Avenue  
Hull, MA 02045

RE: March 2010 Monthly Operating Report

Dear Mr. Petrilak:

Attached is the AOS / United Water, April 2010, Monthly Operating Report illustrating operations and maintenance activities at the Hull WPCF wastewater treatment facilities and the collection system. This report demonstrates activities performed during the period April 1 to April 30, 2010.

April's overall performance was good. There were Thirty-five exceedences of the NPDES Permit.

28 were for exceedences of chlorine residual greater than 1 mg/l. 5 BOD violations from one high test of 78 mg/l and 2 Enterococci from one high test of 2,900 colonies.

We welcome any comments or suggestions for improving this report

Very truly yours,

Pete Nyberg  
Plant Manager  
AOS / United Water

Distribution: Ed Petrilak (1), Pete Nyberg (1), Chuck Terry (1)

