

United Water - AOS
1111 Nantasket Avenue
Hull, Ma 02045-1313
Tel # 781-925-0906
Fax # 781-925-3056



January 11, 2010

Mr. Edward Petrilak
Chief Facility Manager
Town of Hull
Water Pollution Control Facility
1111 Nantasket Avenue
Hull, MA 02045

RE: December 2009 Monthly Operating Report

Dear Mr. Petrilak:

Attached is the AOS / United Water, December 2009, Monthly Operating Report illustrating operations and maintenance activities at the Hull WPCF wastewater treatment facilities and the collection system. This report demonstrates activities performed during the period December 1 to December 31, 2009.

December's overall performance was good. There were two exceedences of the NPDES Permit.

Fecal coliform daily max greater than 264 cfu/100ml, 480 cfu/100. Enterococci monthly average 35 cfu/100 ml, 93 cfu/100 ml

We welcome any comments or suggestions for improving this report

Very truly yours,

Pete Nyberg
Plant Manager
AOS / United Water

Distribution: Ed Petrilak (1), Pete Nyberg (1), Chuck Terry (1)

