

United Water - AOS
1111 Nantasket Avenue
Hull, Ma 02045-1313
Tel # 781-925-0906
Fax # 781-925-3056



March 10, 2010

Mr. Edward Petrilak
Chief Facility Manager
Town of Hull
Water Pollution Control Facility
1111 Nantasket Avenue
Hull, MA 02045

RE: February 2010 Monthly Operating Report

Dear Mr. Petrilak:

Attached is the AOS / United Water, February 2010, Monthly Operating Report illustrating operations and maintenance activities at the Hull WPCF wastewater treatment facilities and the collection system. This report demonstrates activities performed during the period February 1 to February 28, 2010.

February's overall performance was fair. There were seventeen exceedences of the NPDES Permit.

Seven Enterococci daily max 276 cfu/100ml, report 1203,309,1130,560,700,455 cfu/100ml and monthly average 35 cfu/100 ml, report 383 cfu/100 ml. There were also ten exceedences of chlorine residual greater than 1 mg/l.

We welcome any comments or suggestions for improving this report

Very truly yours,

Pete Nyberg
Plant Manager
AOS / United Water

Distribution: Ed Petrilak (1), Pete Nyberg (1), Chuck Terry (1)