

United Water - AOS
1111 Nantasket Avenue
Hull, Ma 02045-1313
Tel # 781-925-0906
Fax # 781-925-3056



February 10, 2010

Mr. Edward Petrilak
Chief Facility Manager
Town of Hull
Water Pollution Control Facility
1111 Nantasket Avenue
Hull, MA 02045

RE: January 2010 Monthly Operating Report

Dear Mr. Petrilak:

Attached is the AOS / United Water, January 2010, Monthly Operating Report illustrating operations and maintenance activities at the Hull WPCF wastewater treatment facilities and the collection system. This report demonstrates activities performed during the period January 1 to January 31, 2010.

January's overall performance was good. There were two exceedences of the NPDES Permit.

Enterococci daily max 276 cfu/100ml, report 387 cfu/100ml and monthly average 35 cfu/100 ml, report 133 cfu/100 ml

We welcome any comments or suggestions for improving this report

Very truly yours,

Pete Nyberg
Plant Manager
AOS / United Water

Distribution: Ed Petrilak (1), Pete Nyberg (1), Chuck Terry (1)

