

United Water - AOS
1111 Nantasket Avenue
Hull, Ma 02045-1313
Tel # 781-925-0906
Fax # 781-925-3056



July 9, 2010

Mr. Edward Petrilak
Chief Facility Manager
Town of Hull
Water Pollution Control Facility
1111 Nantasket Avenue
Hull, MA 02045

RE: June 2010 Monthly Operating Report

Dear Mr. Petrilak:

Attached is the AOS / United Water, June 2010, Monthly Operating Report illustrating operations and maintenance activities at the Hull WPCF wastewater treatment facilities and the collection system. This report demonstrates activities performed during the period June 1 to June 30, 2010.

June's overall performance was very good. There was one exceedence of the NPDES Permit.

One violation was for Enterococci monthly average of greater than 35 cfu/100 ml. Report 55 cfu/100 ml

We welcome any comments or suggestions for improving this report

Very truly yours,

Pete Nyberg
Plant Manager
AOS / United Water

Distribution: Ed Petrilak (1), Pete Nyberg (1), Chuck Terry (1)

