

United Water - AOS
1111 Nantasket Avenue
Hull, Ma 02045-1313
Tel # 781-925-0906
Fax # 781-925-3056



April 8, 2010

Mr. Edward Petrilak
Chief Facility Manager
Town of Hull
Water Pollution Control Facility
1111 Nantasket Avenue
Hull, MA 02045

RE: March 2010 Monthly Operating Report

Dear Mr. Petrilak:

Attached is the AOS / United Water, March 2010, Monthly Operating Report illustrating operations and maintenance activities at the Hull WPCF wastewater treatment facilities and the collection system. This report demonstrates activities performed during the period March 1 to March 31, 2010.

March's overall performance was good. There were twenty-nine exceedences of the NPDES Permit.

They were all for exceedences of chlorine residual greater than 1 mg/l which did allow for enterococci kill of which there were no exceedences. There were also three instances of flow diversion at pumping stations to prevent damage to homes.

We welcome any comments or suggestions for improving this report

Very truly yours,

Pete Nyberg
Plant Manager
AOS / United Water

Distribution: Ed Petrilak (1), Pete Nyberg (1), Chuck Terry (1)