


United Water - AOS
1111 Nantasket Avenue
Hull, Ma 02045-1313
Tel # 781-925-0906
Fax # 781-925-3056



June 10, 2010

Mr. Edward Petrilak
Chief Facility Manager
Town of Hull
Water Pollution Control Facility
1111 Nantasket Avenue
Hull, MA 02045

RE: May 2010 Monthly Operating Report

Dear Mr. Petrilak:

Attached is the AOS / United Water, May 2010, Monthly Operating Report illustrating operations and maintenance activities at the Hull WPCF wastewater treatment facilities and the collection system. This report demonstrates activities performed during the period May 1 to May 31, 2010.

May's overall performance was good. There were Twenty Three exceedences of the NPDES Permit.

22 were for exceedences of chlorine residual greater than 1 mg/l. One violation was for chlorine residual monthly average of greater than 0.7 mg/l

We welcome any comments or suggestions for improving this report

Very truly yours,

Pete Nyberg
Plant Manager
AOS / United Water

Distribution: Ed Petrilak (1), Pete Nyberg (1), Chuck Terry (1)

