

AOS – United Water
1111 Nantasket Avenue
Hull, Ma 02045-1313
Tel # 781-925-0906
Fax # 781-925-3056



MONTHLY OPERATING REPORT

June 2009

EXECUTIVE SUMMARY

There were three odor reports in the month of June. They will be discussed in the next section

The holding tank aeration system has been installed and is operational. There is very little odor when processing sludge with the RST (rotating sludge thickener).

Bolts were replaced in primary tank #2 mechanism. The bolts were replaced with stainless steel as had been discussed. We are awaiting dry weather to recoat the bolts and steel framework.

Fall River Electric has been installing conduit and control panels for the new SCADA system.

The generator at Station 3 has been repaired. When preventative maintenance testing of the generators was performed a short circuit was discovered in the control panel.

Heavy cleaning of the 30 inch line on Topics Road was performed. The camera was then sent down the line to observe H₂S corrosion.

A tour was given to the fifth grade class from the Jacobs School.