

United Water - AOS
1111 Nantasket Avenue
Hull, Ma 02045-1313
Tel # 781-925-0906
Fax # 781-925-3056



MONTHLY OPERATING REPORT

May 2010

EXECUTIVE SUMMARY

There were no odor reports in the month of May.

Setting up a bisulfate system for dechlorination.

Station #1 pump #1 has been rebuilt and has been installed. The mechanical seal was leaking

The spring session of cleaning and camering has been completed by National Watermain.

The level transducer at Station 9 has been changed. A clean water type of transmitter had been installed which could be fouled by wastewater and was replaced with the birdcage type which is more robust.

Influent pump #2 VFD was replaced. The old VFD had failed.

The bisulfate system was made operational on May 21. Since that time we have had no exceedences of the chlorine residual or of the bacteria limits.