

United Water - AOS  
1111 Nantasket Avenue  
Hull, Ma 02045-1313  
Tel # 781-925-0906  
Fax # 781-925-3056



## **MONTHLY OPERATING REPORT**

### **October 2009**

#### **EXECUTIVE SUMMARY**

There were no odor reports in the month of October.

Work on the new SCADA system is proceeding. Some instruments have been changed to the new system

Aeration tank influent slide gates have been wired for control from SCADA. The contractor will terminate the wires and set up the operating program. This work was completed as a capital improvement

The limit switches were set on the aeration gates so that they will stop in their proper place.

Piping and valves were changed in the secondary gallery. We had been unable to isolate the secondary clarifiers as the valves would not seat. This work was completed as a capital improvement.

The fall cleaning and cameraing was completed. 20,000 feet of pipe were cleaned and 5,110 feet of pipe were camerad.