

**MONTHLY OPERATING REPORT**  
**April 2008**

**EXECUTIVE SUMMARY**

There were no odor reports in the month of April.

Two of the hoists on site received service. A new chain was installed and a new motor was installed by our Contractor.

The generator at Station #5 was repaired. The radiator was replaced. While performing maintenance on the generator it was discovered that the radiator was in poor condition. This was performed as a capital item.

Return sludge pump #3 has been repaired and returned to service. The impeller was damaged and has been replaced. This was performed as a capital item

It has been determined that secondary clarifier #1 has a bad seal the same as #2 which has been replaced. We have contracted with Waterline Industries to perform this repair.

Groundskeeping at the pumping stations and the plant has been started for the season.

The generator at station #6 has been repaired. The ignition coil required replacement

The sludge thickening unit has been serviced and is ready for use. We anticipate starting the unit within the next couple of weeks.