


AOS – United Water
1111 Nantasket Avenue
Hull, Ma 02045-1313
Tel # 781-925-0906
Fax # 781-925-3056



EXECUTIVE SUMMARY

There were no odor reports in the month of April.

Flow meters have been calibrated by our contractor, EIS. This is an annual calibration.

Pioneer Electric has completed the upgrade of fittings and electrical repair on Gravity Thickener #1.

The contractor, Comeau Services, has started work on the Holding Tank #2 Aeration System. They expect to complete the work by the end of May.

Groundskeeping at the pumping stations and the plant has been started for the season.

Schooner's Restaurant called and reported a blockage in their line. It has been decided by Mr. Petrilak that we will no longer be responsible for their line blockage due to grease build up from their not cleaning their grease trap.