

United Water - AOS
1111 Nantasket Avenue
Hull, Ma 02045-1313
Tel # 781-925-0906
Fax # 781-925-3056



MONTHLY OPERATING REPORT

April 2011

EXECUTIVE SUMMARY

There were no odor reports in the month of April.

Primary Clarifier #1 has been taken off line. As an odor control measure we try not to run primary #1 during the summer months as it is located closest to Spring St.

Primary and secondary galleries have had the piping and valves painted for corrosion control.

The gardens around the plant have been cleaned up and mulched. There had been a fair amount of storm damage to the gardens which has been repaired.

The Rotating Sludge Thickener (RST) has been prepared for use. Polymer has been ordered, new drive sprockets have been installed, the gear reducers have had oil changes, the polyblend unit has been cleaned, the sludge pumps have been serviced and the spray wash bar nozzles have all been cleaned.

The emergency generator at station #3 has been repaired. The radiator was leaking and has been re-cored as it was so old a replacement does not exist. A stand by generator was provided by our contractor, Power Up, so emergency power was available while the radiator was being repaired.

Our instrumentation contractor, EIS, has connected a flow signal to the samplers so that a flow proportioned sample can be taken as required by the NPDES permit. This was an item that was discovered in the audit performed last month.