


United Water - AOS
1111 Nantasket Avenue
Hull, Ma 02045-1313
Tel # 781-925-0906
Fax # 781-925-3056



MONTHLY OPERATING REPORT

April 2012

EXECUTIVE SUMMARY

There was one odor report in the month of April.

Several painting projects were undertaken to improve facility appearance. The garage doors were painted, the back stairwell and the floor on the basement level.

New seals were installed on all floodgates and doors and these were painted after installation.

All yard equipment has been serviced and readied for the upcoming season.

The gardens around the plant have been cleaned of winter debris and a layer of mulch has been laid down.

A new high pressure hose has been installed on the jetter unit. The hose was leaking and was repaired twice and was found to be unrepairable so a new hose was purchased.

New shelving for the hypochlorite feed pumps was installed and a new pump to feed hypo to the odor scrubber was installed..