

United Water Environmental Services - AOS
1111 Nantasket Avenue
Hull, Ma 02045-1313
Tel # 781-925-0906
Fax # 781-925-3056



MONTHLY OPERATING REPORT

December 2012

EXECUTIVE SUMMARY

There were no odor reports in the month of December.

Station 3, pump #2 has been rebuilt. A new volute, impeller, bearings and mechanical seal were installed.

Influent pump #1 VFD board has been replaced and the bucket had to be relocated as it was not making contact with the buss in the MCC.

Flying Santa arrived for the Lifesaving Museum.

Primary clarifier was put into service for high flow from the storm on 12-18.

The step screen is out of service, it needs new switches which have been ordered. The Lakeside has been put into service

Replacement piping and valves for the secondary gallery have been delivered and will be installed over the next two months