

United Water Environmental Services - AOS
1111 Nantasket Avenue
Hull, Ma 02045-1313
Tel # 781-925-0906
Fax # 781-925-3056



MONTHLY OPERATING REPORT

February 2013

EXECUTIVE SUMMARY

There were no odor reports in the month of February.

Station #1 pump #2 has been rebuilt , volute replaced and the pump has been returned to service.

Secondary clarifier #1 has had its drive gears and chain replaced.

Removed RAS valve in aeration tank #4 as it was leaking.

Inlandwaters was here to clean the wetwell at station #3. The rags were causing the pumps to clog. The wetwell had been cleaned in August 2012.

Power Up was on site to service all generators. This was a minor service.

Station 9 pump #1 shaft broke and a new shaft has been ordered and the pump repaired and returned to service.

Waterline Industries was on site and completed repair of the grit screw packing gland.

On February 28, 2013 the influent pump room flooded as well as 5feet of water in the mechanical room flooding all electrical switchgear on that level.