


United Water - AOS
1111 Nantasket Avenue
Hull, Ma 02045-1313
Tel # 781-925-0906
Fax # 781-925-3056



MONTHLY OPERATING REPORT

January 2011

EXECUTIVE SUMMARY

There were no odor reports in the month of January.

Power was restored to the secondary gallery. The storm on December 27, had flooded manholes allowing water to get in to the conduit which caused short circuits. A new circuit breaker panel has been installed as well as some wiring replaced and repairs to the clarifier drives.

There were two failures of the force main from Station 9. January 7 and again on January 19. Repairs were performed by Hub Construction.

The building heating system received further repairs. All three oil burners are operating now.

The wash press has been repaired and returned to service. The press required a major overhaul with all new factory parts. The Lakeside unit is still under repair due to long lead time to get repair parts.