

United Water Environmental Services - AOS  
1111 Nantasket Avenue  
Hull, Ma 02045-1313  
Tel # 781-925-0906  
Fax # 781-925-3056



## **MONTHLY OPERATING REPORT**

### **January 2013**

#### **EXECUTIVE SUMMARY**

There were no odor reports in the month of January.

The grit chamber work has been completed. The new grit screw has been installed and the spalled concrete has been resurfaced.

Both the Lakeside and the Huber Step Screen have been repaired. They had electrical issues where switches and contactors had to be replaced as well as some SCADA reprogramming.

Laboratory instruments have had their annual calibrations.

Annual fire extinguisher inspections have been performed.

Annual flow meter calibrations have been performed

The boiler system has required more work, there was a bad relay which would not allow the boilers to run replaced so all three boilers are now available.