

United Water Environmental Services - AOS
1111 Nantasket Avenue
Hull, Ma 02045-1313
Tel # 781-925-0906
Fax # 781-925-3056



MONTHLY OPERATING REPORT

June 2012

EXECUTIVE SUMMARY

There were five odor reports in the month of June.

RAS #2 motor has been rebuilt and reinstalled ready for use .

Primary clarifier #2 has been put into service and primary #1 has been removed from service so that the clarifier furthest from Spring St . is on line for odor control.

EIS was on site to work on the SCADA system, installing a new touch screen panel for the step screen. This will allow for control of the step screen

DEP, David Burns, was on site for an inspection. No issues were found and he will send a letter that he was satisfied as to the operation of the facility.

We continue to run the rotating sludge thickener to thicken the secondary sludge.

Enclosed are the capital plan results from 2011- 2012

Enclosed is a projection for 2012-2013 capital plans