

United Water - AOS
1111 Nantasket Avenue
Hull, Ma 02045-1313
Tel # 781-925-0906
Fax # 781-925-3056



MONTHLY OPERATING REPORT

March 2012

EXECUTIVE SUMMARY

There were no odor reports in the month of March.

The RST discharge auger pump has been repaired and reinstalled. New side plates were fabricated and ceramic coating was applied in an effort to protect the metal from deterioration.

The odor scrubber media has been acid washed to try to improve efficiency.

EIS, our instrumentation contractor, has provided annual calibration of flow meters for RAS, WAS, effluent and chlorine residual meter.

The RAS collection pit has been cleaned. We had noticed that the pump flow had reduced. The suction line was checked for blockages which was negative but material was removed from the inlet bell and flow has been restored.

A new high pressure hose has been installed on the jetter unit. The hose was leaking and was repaired twice and was found to be unrepairable so a new hose was purchased.

New shelving for the hypochlorite feed pumps was installed and a new pump to feed hypo to the odor scrubber was installed..