

United Water Environmental Services - AOS
1111 Nantasket Avenue
Hull, Ma 02045-1313
Tel # 781-925-0906
Fax # 781-925-3056



MONTHLY OPERATING REPORT May 2012

EXECUTIVE SUMMARY

There were three odor reports in the month of May.

DEP inspected the UST and sent a letter of non-compliance due to the vent pipe being wrong. The vent pipe has been repaired and now meets code.

Pioneer Electric has been on site to repair the emergency lights, building lighting, switches, and receptacles.

EIS was on site to work on the SCADA system, installing alarms and a tank level gauge for the thickened sludge tank in the garage.

Inland Waters was in Town to complete this years cleaning and camera work.

Comeau Services was on site to continue with Secondary Gallery piping replacement.

Hull Glass was on site to repair a broken window at the top of the stairway and reseal several windows on the East side of the building that were leaking.

The rotating sludge thickener has been put into service to thicken the waste activated sludge.