United Water - AOS 1111 Nantasket Avenue Hull, Ma 02045-1313 Tel # 781-925-0906 Fax # 781-925-3056



MONTHLY OPERATING REPORT September 2011

EXECUTIVE SUMMARY

There were eight odor reports in the month of September. They will be discussed in the next section.

A bad modem was diagnosed at Station #4. It has been replaced with the modem from D Street. A new modem for D Street will be purchased.

A new pump was installed in the odor scrubber solution tank. The previous pump burned out.

Secondary #1 has been repaired again. A new skimmer support was installed, the seal between the inflow and RAS flow was repaired, many bolts throughout the mechanism have been replaced with stainless steel and new sacrificial anodes were installed.

The Lakeside screening unit has been rebuilt and returned to service. New conduit and wiring were installed, a new processor was programmed and installed and much welding and fitting were completed.

SCADA issues have been resolved, a bad power supply has been replaced in the effluent control panel and the blower system logic has been repaired.