


AOS – United Water  
1111 Nantasket Avenue  
Hull, Ma 02045-1313  
Tel # 781-925-0906  
Fax # 781-925-3056



June 10, 2009

Mr. Edward Petrilak  
Chief Facility Manager  
Town of Hull  
Water Pollution Control Facility  
1111 Nantasket Avenue  
Hull, MA 02045

RE: May 2009 Monthly Operating Report

Dear Mr. Petrilak:

Attached is the AOS / United Water, May 2009, Monthly Operating Report illustrating operations and maintenance activities at the Hull WPCF wastewater treatment facilities and the collection system. This report demonstrates activities performed during the period May 1 to May 31, 2009.

May's overall performance was very good. There was one exceedence of the NPDES Permit. We exceeded the daily maximum for fecal coliform. The result was 909 /100 ml. Our limit is 260.

We welcome any comments or suggestions for improving this report

Very truly yours,

Pete Nyberg  
Plant Manager  
AOS / United Water

Distribution: Ed Petrilak (1), Pete Nyberg (1), Chuck Terry (1)