

## Dilorio, Chris

---

**From:** Ahlquist, Roy  
**Sent:** Thursday, November 30, 2023 1:30 PM  
**To:** Dilorio, Chris  
**Subject:** Paragon dunes project

Chris,

As we discussed in our meeting yesterday here a couple of concerns on behalf of the fire department. Is there a dry piped standpipe system in the 1<sup>st</sup> floor parking area that is attached to the main fire protection system and fire pump? If not, it will be needed. Also they will need to perform a radio test in accordance with 780 CMR sect 916 EMERGENCY RESPONDER RADIO COVERAGE, NFPA 72 to determine if a BDA is needed. Let me know if you have any other questions or concerns. Hope this helps.

Thanks,

Captain Roy W. Ahlquist III  
Fire prevention officer  
Hull Fire department  
253 Atlantic Ave. 2<sup>nd</sup> floor  
Hull, Ma. 02045  
781-925-1350 (o)  
781-427-4741 (c)  
781-925-2228 (f)